

1088500021

Identification Number

08/16/2019

Date Issued

Status Code: 1

PUBLIC SWIMMING POOL OPERATION PERMIT

Permission is granted to TOXAWAY VIEWS of TOXAWAY VIEWS POOL
HOMEOWNERS ASSN INC. *Owner or Operator* *Name of Public Swimming Pool*

to operate a public swimming pool as defined in G.S. 130A-280 and 15A NCAC 18A .2500 at

101 POOL ROAD, LAKE TOXAWAY, NC 28747

Street Address of Pool Location

Transylvania

County

Type of Pool: (check one)

- Swimming Pool
 Wading pool
 Spa
 Specialized
 Other (describe) _____

Signed: Maile O. Cash REHS Agent
N.C. Department of Health and Human Services
Environmental Health Section

Expiration Date: 10/31/2019

Remarks: No night swimming.

INSTRUCTIONS

Purpose: General Statute 130A-281 states "No public swimming pool may be opened for use unless the owner or operator has obtained an operation permit issued by the Department". General Statute 130A-282 requires the Commission for Public Health to adopt rules including requirements for application review, expiration, renewal, and revocation or suspension of an operating permit. Those rules are contained in 15A NCAC 18A .2500.

This form is to be used as the permit specified above.

Preparation: Local environmental health specialists shall issue a permit every time a new or reissued permit is indicated. Prepare an original and one copy for:

1. Original given to pool owner or operator.
2. Copy for the local health department.

In the event the permit/transitional permit is suspended or revoked, complete the Suspension/Revocation form (EHS 4009B).

Disposition: This form may be destroyed in accordance with Standard 8.B.6., Inspection Records, of the *Records Disposition Schedule* published by the N.C. Division of Archives and History.

Additional forms may be ordered from: Environmental Health Section
1632 Mail Service Center
Raleigh, NC 27699-1632
(Courier 52-01-00)

Inspection of Swimming Pool

Date of Insp./Chg: 08 / 16 / 2019

Current Facility ID 1088500021

Status Code: A

Old Facility ID

Water Supply: Municipal/Community On-Site Supply
Wastewater: Municipal/Community On-Site System

Water sample taken today? Inspection Name Change
 Re-inspection Verification of Closure
 Visit Status Change

Name of Establishment: TOXAWAY VIEWS POOL

Pool Operator: Rita
(F, L) Ferin

Location Address: 101 POOL ROAD

Mailing Addr. P.O. BOX 2429

City: LAKE TOXAWAY State: NC Zip: 28747

City: CASHIERS State: NC Zip: 28717

* Indicates critical item (6-point demerit)

WATER QUALITY: (.2535)

- *1. Water clear enough to clearly see bottom of pool and pool drain 6
- *2. Disinfectant residual provided by:
 - free chlorine = 1.5 . 0 (at least 1.0 ppm or 2.0 ppm where required);
 - bromine = . . . (at least 2.0 ppm); or
 - biguanide = . . . (30 to 50 ppm)..... 6
- *3. Pool water pH = 7.3 (7.2 to 7.8)..... 6
- *4. Water temperature of heated pool 79 . 0 °F; does not exceed 90°F (swimming pool) or 104°F (spa) 6
- 5. Daily written records of water quality and test kit kept on site 4

Comments:
** SEE COMMENT SHEET ATTACHED **

Alk 80, CYA 60

Ref. Inspection done 8/15/19

POOL MAINTENANCE:

- *6. Main drain covers secured and in good repair, no suction hazard. Single drains protected by April 1, 2006 (.2537, .2539)..... 6
- 7. Pool walls and floor kept clean, free of debris and in good repair (.2537).... 4
- 8. Surface skimmers (with weirs, baskets and covers) or gutters clean, in good repair, and functioning properly, no floating debris (.2518, .2537) 4
- 9. Depth markings and no diving markers or signs visible and properly located (.2523, .2537)..... 4
- 10. Safety ropes with floats and contrasting color bands provided at shallow area breakpoints (.2515, .2523)..... 2
- 11. Diving equipment, ladders, steps and handrails properly placed, in good repair (.2517, .2521)..... 2
- 12. Inlets and other fittings in place and in good repair (.2537)..... 4
- 13. Contrasting band on steps and benches (.2521, .2516, .2532)..... 4
- 14. Spa timer working properly (.2537)..... 4

#16 wooden Gate corrected

PREMISES:

- *15. Body hook and ring buoy with throw rope or lifeguard with rescue tube provided and properly located (.2530, .2537) 6
- 16. Fence or barrier with self-closing, self-latching gates properly constructed and maintained (.2528, .2537) 4
- 17. Decks unobstructed, properly drained, free of trip hazards (.2522, .2537)..... 4
- 18. Lifeguards present or warning signs posted (.2530) 4
- 19. Signs prohibit glass containers or pets in pool area (.2530) 4
- 20. Caution signs posted at hot water spas (.2532) 4
- 21. Pool and deck lighting provided at pools that operate at night (.2524, .2537) ... 4
- *22. Emergency telephone provided (.2530) 6

#18 No Lifeguard signs corrected

EQUIPMENT ROOM:

- 23. Chlorine or bromine automatic feeders that meet NSF Standard 50 (.2535) 4
- 24. Approved pump, filter, and flow meter operating properly (.2518, .2519) 4
- 25. Equipment and chemicals kept in a dry, well-ventilated enclosure (.2533, .2534, .2537) 2
- 26. Valves and pipes identified by color codes or labels (.2518) 2
- 27. Filter backwash discharged through an air gap (.2513) 2

DRESSING AND SANTARY FACILITIES:

- 28. Bathroom or rest rooms accessible; shower sign posted (.2526) 2
- 29. Required fixtures provided, clean, and in good repair (.2526) 2
- 30. Approved water source, no cross connections (.2512) 2
- 31. Sewage disposed of in a properly operating sewage system (.2513) 2
- 32. Floors smooth, slip-resistant, kept clean (.2526) 2
- 33. Hose bibbs and floor drains provided (.2526) 2

Comment Sheet Attached

Yes No

Report Received by:

Don A Woods

Inspection Conducted by: Michelle Cary REHS

EHS I.D. # 1870 - Neill Cagle

Division of Environmental Health

COMMENT ADDENDUM

Name: TOXAWAY VIEWS POOL

ID: 1088500021

Street: 101 POOL ROAD

City: LAKE TOXAWAY

Time In: 02 : 48 am pm

Time Out: 3 : 15 am pm

Total Time: 27 minutes

